

Certificate of Conformity

Registered No.:

COC PVP11009/22E-01

File reference
PVP11009/22E-01

Test report No.
TRPVP11009/22E/01

Date of issue
2022-12-19

On the basis of the tests undertaken, the samples of the below product(s) have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out:

Applicant: **Shenzhen ATESS Power Technology Co., Ltd**
1st Floor of Building 3 at Sector B and 3rd Floor of Building 9, Henglong Industrial Park, No.4 Industrial Zone, Shuitian Community, Shiyan Street, Baoan District, Shenzhen

Manufacturer: **Shenzhen ATESS Power Technology Co., Ltd**
1st Floor of Building 3 at Sector B and 3rd Floor of Building 9, Henglong Industrial Park, No.4 Industrial Zone, Shuitian Community, Shiyan Street, Baoan District, Shenzhen

Factory: **Shenzhen ATESS Power Technology Co., Ltd**
1st Floor of Building 3 at Sector B and 3rd Floor of Building 9, Henglong Industrial Park, No.4 Industrial Zone, Shuitian Community, Shiyan Street, Baoan District, Shenzhen

Product: Bidirectional Battery Inverter

Type designation: PCS100, PCS250, PCS500, PCS630
Three-phase, Firmware version: PCS50k_630k_HV3_SV1.6.16_APP

Certification program: BOS-P-01 Rev. 00

Certification fundamental(s): EN 50549-1:2019+AC:2019-04
See test report for detailed information.

This document is based on the evaluation of the samples of the above mentioned product(s). It does not imply an assessment of the mass-production of the product(s), and it does not permit the use of a TÜV NORD mark. The holder of this document may use it in connection with the related test report(s).



Renewable Energy

ESS-T-011 COC



中国认可
产品
PRODUCT
CNAS C183-P

Page 1 of 1

TÜV NORD (HANGZHOU) CO., LTD.
Member of TÜV NORD Group
Tel: +86-571-85386989
Fax: +86-571-85386986
www.tuv-nord.com/cn
P.R. China

Version 1.3