

Certificate of Conformity

By the product certificate number

No. 2623/0103-CER

Issued to:

License holder:

Shenzhen Ateess Power Technology Co., Ltd
2nd Floor, No.23 Zhulongtian Road, Shuitian Community, Shiyan Street, Baoan District,
Shenzhen, Guangdong, P.R. China

Trademark:



Manufacturer:

Shenzhen Ateess Power Technology Co., Ltd
2nd Floor, No.23 Zhulongtian Road, Shuitian Community, Shiyan Street, Baoan District,
Shenzhen, Guangdong, P.R. China

It is certified that the product:

Type of product: Hybrid Inverter

Models:	HPS100	HPS120	HPS150
Rated characteristics:			
Rated Power	100000 W	120000 W	150000 W
Rated Voltage		400 V _{ac}	
Rated Frequency		50 Hz	
Firmware version	DSP: HPS30K_150K_HV3_SV4.1.14_APP50549_24 LCD: HPS30_150K_FLEXEMScreen_HV1.0_SV9.0.3		
Number of phases	Three Phases (3/N/PE)		
Isolation transformer	Yes		

Is in compliance with the standard:

- **Technical Prescription C10/11 of Synergrid. Edition 2.2 (15.03.2021) (1)**

(1) Equipment considered to be connected to power generating plants of Type A (< 1 MW) to the low voltage grid (≤1kV)

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-35 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 04th of April 2023. This certificate is valid until the 04th of April 2028.

Madrid, 04 de abril de 2023.

Daniel Arranz Muñiz
Certification Manager

